



NOTE:
 REDUCED PRESSURE BACKFLOW PREVENTER SHALL BE LOCKABLE



STANDARD CONSTRUCTION DETAIL
 LIFT STATION POTABLE WATER SERVICE
 (WHERE RECLAIM WATER NOT AVAILABLE)

REV. 12/08

FILE NAME:

S21.DWG

DETAIL REF:

S-21