

CITY OF PORT ORANGE

SLOPED ROOF INFORMATION

PLEASE PRINT

120 MPH WIND ZONE

Skylights Yes-If yes, Review Required w/Installation Instruction & Testing Report. No

Deck Type _____

Underlayment ASTM D 226 TYPE 1 or ASTM D 4869 TYPE 1
Weight _____ Layers _____

Insulation _____ N/A


Cap Sheet _____ N/A

Roof Covering Manufacturer- ASPHALT SHINGLES TO COMPLY WITH
 ASTM D 225 OR ASTM D 3462

Fasteners ATTACHMENT SHALL CONFORM WITH
ASTM D 3161 OR M-DC PA 107-95

Drip edge _____

Number of Squares _____

“  12”
roof slope

Square Footage Under Roof _____

Mean height _____

Contractor: _____

Owner: _____

Job Site: _____

**** Note:** A product wrapper containing the product approval information needs to be placed with the permit placard for RODI (underlayment), ROFL (flashing), and ROOF (final installation) inspections.

Revised
01/26/10

****Re-roof permits require a minimum of three inspections:**
RODI – Dry In
ROFL – Flashing
ROOF – Final Installation

FASTENERS to be corrosion resistant conforming to 1506 FBCB.

UNDERLAYMENT to comply with 1507.

ASPHALT SHINGLES to comply with 1507.2 FBCB

FLASHING to comply with 1507 FBCB

DRIP EDGE to comply with 1507 FBCB

FBCB = FLORIDA BUILDING CODE, BUILDING