



**NOTES:**

1. ON TRANSITIONS BETWEEN LARGER DIAMETER AND SMALLER SEWER COLLECTORS, OR THE TOP OF THE INSIDE OF THE TWO SEWER PIPES SHALL BE MATCHED.
2. NON-PENETRATING PICK-HOLES IN ALL CONCRETE SECTIONS.
3. USE FARBERTITE BITUMASTIC SEALER BETWEEN SECTIONS OF MANHOLES.
4. 0.1' - DROP ACROSS MANHOLE TYP.
5. MAXIMUM DEPTH NOT TO EXCEED 15.0 FEET MEASURED FROM MANHOLE TOP TO INSIDE BOTTOM.



**STANDARD CONSTRUCTION DETAIL  
STANDARD MANHOLE**

REV. 12/08

FILE NAME:

S6.DWG

DETAIL REF:

**S-6**