



**NOTES:**

1. DRIVEWAY TO BE 6" THICK 3000 PSI CONCRETE AT 28 DAYS WITH 6x6 10/10 W.W. MESH. BASE TO BE COMPACTED AND TESTED TO 98% DENSITY WITH MINIMUM L.B.R. 40 BASED ON A.A.S.H.T.O. T-180 MODIFIED PROCTOR TEST.
2. IF RECLAIMED WATER IS UNAVAILABLE FOR LIFT STATION WATER SERVICE, CONTRACTOR SHALL USE POTABLE WATER.
3. 12.0' HAMMERHEAD DRIVEWAY OUTSIDE FENCE MAY BE REQUIRED DEPENDS ON SITE CONDITION.
4. FENCE MAY BE RELOCATED INTERNALLY WITHIN SITE TO CREATE A 25' X 25' SITE IF LANDSCAPING MATERIALS ARE INSTALLED AROUND THE PERIMETER. ANY FENCE MATERIAL DEVIATIONS WILL REQUIRE MAINTENANCE BY OWNER / DEVELOPER.
5. FINISH GRADE OF LIFT STATION SITE SHALL BE EQUAL TO OR GREATER THAN THE ELEVATION OF THE CENTERLINE OF ADJACENT ROADWAY & THERE MUST BE POSITIVE DRAINAGE AT & SURROUNDING THE SITE.



**STANDARD CONSTRUCTION DETAIL  
TYPICAL LIFT STATION SITE PLAN**

REV. 12/08

FILE NAME:

S19.DWG

DETAIL REF:

**S-19**