



**NOTE:**

1. THE FOLLOWING MATERIALS ARE PERMITTED TO BE USED AS A STABILIZED WALKWAY:
  - A. COMPACTED CRUSHED MINERAL AGGREGATE
  - B. COMPACTED CRUSHED SHELL
  - C. OTHER MATERIALS APPROVED THROUGH THE SDRC PROCESS.
2. CONCRETE AND ASPHALT SHALL BE USED IN HIGH-TRAFFIC AREAS.
3. MULCH SHALL NOT BE USED AS A STABILIZED WALKING PATH MATERIAL.
4. THE FINAL GRADE OF THE WALKPATH SHALL BE GRADED WITH A MAXIMUM 2.08% CROSS-SLOPE AWAY FROM THE CENTERLINE OF THE PATH.
5. METAL LANDSCAPE EDGING IS TO BE INSTALLED SUCH THAT THE TOP OF THE EDGING IS TO BE AT OR BELOW THE CROWN OF THE WALKING PATH, BUT NOT MORE THAN 3" ABOVE FINISHED GRADE.



STANDARD CONSTRUCTION DETAIL  
STABILIZED WALKING PATH

REV. 12/18

FILE NAME:

M10.DWG

DETAIL REF:

**M-10**