



NOTE:

1. RAISED SIDEWALKS ADJACENT TO BUILDINGS MAY BE USED IN LIEU OF WHEEL STOPS, PROVIDING THE SIDEWALK IS NOT LESS THAN 7' WIDE (LDC, CHAPTER 12, SECTION 6(G)(2)).
2. A 44" WIDE MINIMUM CLEAR ACCESSIBLE ROUTE MUST BE PROVIDED AT ALL TIMES.
3. ACCESSIBLE PARKING SPACES AND ACCESS AISLES SHALL BE LEVEL WITH SURFACE SLOPES NOT EXCEEDING 1/4"/1' OR 2.08% IN ALL DIRECTIONS.
4. WHERE PARKING SPACES ARE MARKED WITH LINES, WIDTH MEASUREMENTS OF PARKING SPACES AND ACCESSIBLE AISLES SHALL BE MADE FROM CENTERLINE OF THE MARKINGS,
5. WHERE PARKING SPACES OR ACCESS AISLES ARE NOT ADJACENT TO ANOTHER PARKING SPACE OR ACCESS AISLE, MEASUREMENTS SHALL BE PERMITTED TO INCLUDE THE FULL WIDTH OF THE LINE DEFINING THE PARKING SPACE OR ACCESS AISLE.
6. LINE WIDTHS FOR ACCESSIBILITY SYMBOL AND STRIPING, AND ANGLE OF ACCESS AISLE STRIPING ARE RECOMMENDED MEASUREMENTS.



STANDARD CONSTRUCTION DETAIL
ACCESSIBLE PARKING LAYOUT

FILE NAME:

M14.DWG

DETAIL REF:

M-14

REV. 12/18