



NOTES:

1. HYDRANTS SHALL BE BREAK AWAY TYPE WITH PUMPER NOZZLE FACING STREET.
1. HYDRANTS SHALL BE NON-DRAINING TYPE.
2. HYDRANTS TO BE PAINTED EMERGENCY YELLOW AT MANUFACTURE-EPOXY OR POLYURETHANE.
3. HOSE BIBBS TO BE AMERICAN STANDARD THREADS.
4. ADJUSTABLE TRENCH ADAPTOR ASSEMBLY REQUIRED FOR ALL VALVES GREATER THAN 36" DEEP.
5. INSTALL AT SIDE LOT LINES OR AT CORNERS OF ROADWAY INTERSECTIONS (TYP.).
6. ALL OUTSIDE HEX NUTS, BOLTS AND HARDWARES (EXCEPT MECHANICAL BOLTS SUCH AS "T" BOLTS) SHALL BE MINIMUM 316 STAINLESS STEEL GRADE.
7. THE INTERNAL UPPER AND LOWER STEM SHALL BE MINIMUM 304 STAINLESS STEEL GRADE.



STANDARD CONSTRUCTION DETAIL
FIRE HYDRANT ASSEMBLY

REV. 12/18

| | |
|-------------|-------------|
| FILE NAME: | W20.DWG |
| DETAIL REF: | W-20 |