



NOTES:

1. PIPE TO BE DEFLECTED AROUND A DRAINAGE INLET SHALL BE RESTRAINED IN ACCORDANCE WITH DIPRA (LATEST EDITION). RESTRAINT GUIDELINES TO BE ADAPTED TO PVC PIPE AS NECESSARY.



STANDARD CONSTRUCTION DETAIL
 MAIN INSTALLATION BETWEEN
 DRAINAGE INLET AND SIDEWALK

REV. 12/18

FILE NAME:

W24.DWG

DETAIL REF:

W-24