



LOCKSEAL	
ITEM #	DESCRIPTION
93280148	HEAD WITH ALUMINUM SEAL
93210140	REGULAR DIAMETER STUD
93280139	KEY

NOTE:

1. ALL VALVES SHALL BE FULL PORT.
2. DEVELOPER SHALL PROVIDE AND INSTALL BULLET LOCKS ON ALL VALVES PRIOR TO FINAL ACCEPTANCE.
3. POLYTUBING SHALL BE CONTINUOUS WITH NO COUPLINGS.



STANDARD CONSTRUCTION DETAIL
 3/4"–1" METER SIZES POTABLE WATER
 SERVICE CONNECTION

REV. 12/18

FILE NAME:
 W5.DWG
 DETAIL REF:
W-5