



M A T E R I A L S
 2" – COPPER OR BRASS
 4" TO 10" – DIP

ITEM	QUANT.	DESCRIPTION
1	2	90° BEND (FLG. & FLG.)
2	1	2"-10" BACKFLOW PREVENTER
3	2	90° BEND (MJ. & MJ.)

NOTES:

1. ALL DEVICES SHALL BE PAINTED TO COMPLY WITH FLORIDA ADMINISTRATIVE CODE CHAPTER 62-555 AND THE FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION CROSS-CONNECTION CONTROL PROGRAM, AS FOLLOWS:

- WATER MAIN – BLUE
- FIRE MAIN – RED
- RECLAIM WATER MAIN – PURPLE

2. LENGTH OF SPOOL PIECES BEFORE AND AFTER METER BASED ON METER MANUFACTURER'S RECOMMENDATION.



STANDARD CONSTRUCTION DETAIL
 2"-10" METER WATER SERVICE W/
 BACKFLOW PREVENTER

REV. 12/18

FILE NAME:

W10.DWG

DETAIL REF:

W-10