

GATE OR  
BALL VALVE

4" GIP  
NIPPLE (3X)

GIP 90  
ELBOW (2X)

COMPRESSION  
FITTING (2X)

POLY TUBING  
RISER (2X)

RESTRAINED JOINTS  
AS REQUIRED (TYP.)

PUBLIC  
SIDE

2" DIAMETER ASSEMBLY

CUSTOMER'S  
SIDE

IRON COMPRESSION  
COUPLING

18" MIN.

43"

MINIMUM SPACE REQUIRED  
PUBLIC UTILITIES 2" WATER  
METER AND 2" BACKFLOW  
PREVENTION DEVICE

FINISHED GRADE

NOTE:

1. PROVIDE SUPPORT OR PROTECTIVE POSTS UNDER METER AND BACKFLOW PREVENTION DEVICE.



STANDARD CONSTRUCTION DETAIL  
2" TEMPORARY METER ASSEMBLY

REV. 12/18

FILE NAME:

W14.DWG

DETAIL REF:

**W-14**