



NOTES:

1. TAPPING OF MAINS SHALL BE PERFORMED BY THE CITY AND BILLED IN ACCORDANCE WITH THE ADOPTED FEE RESOLUTION. ALL MATERIALS TO BE PROVIDED BY DEVELOPER/CONTRACTOR.
2. EXCAVATIONS FOR TAPPING WORK TO BE SAFE, SECURE AND DRY, WITH 6" THICK (MIN.) LAYER OF #57 STONE AT BOTTOM.
3. CITY ALLOWS ONLY 1", 2", 4", 6", 8", 10" AND 12" TAPS.
4. REQUIRED RESTRAINED JOINTS TO BE INSTALLED – THRUST BLOCKS ARE NOT PERMITTED.
5. EPOXY COATED STEEL, STAINLESS STEEL SLEEVES WITH 316 STAINLESS STEEL BOLTS ARE PERMITTED FOR ALL TYPES OF PIPE MATERIALS.
6. ALL VALVES 2" OR GREATER SHALL BE GATE VALVES. CORPORATION STOPS ALLOWED ON BLOW-OFFS ONLY.



STANDARD CONSTRUCTION DETAIL
TAPPING VALVE AND SLEEVE

REV. 12/18

FILE NAME:

W15.DWG

DETAIL REF:

W-15