



**NOTES:**

1. THIS DETAIL SHALL BE UTILIZED ON ALL WATERLINE EXTENSIONS. THE CITY WILL ALLOW A DIRECT CONNECTION TO THE CITY'S DRINKING WATER SYSTEM AT ONLY ONE POINT OF CONNECTION.
2. FINAL SECONDARY TIE-INS SHALL BE PERFORMED AFTER CLEARANCE FROM FDEP.
3. PROVIDE SUPPORT AND/OR PROTECTIVE MEASURES TO PREVENT ABOVE GROUND PIPE BEING BROKEN.
4. DIRECT TIE-IN METHOD ALLOWED WHEN TIE-IN UNDER EXISTING PAVEMENT LIMITS.



STANDARD CONSTRUCTION DETAIL  
TEMPORARY JUMPER CONNECTION

REV. 12/18

FILE NAME:

W16.DWG

DETAIL REF:

**W-16**