



M A T E R I A L S		
ITEM	QUANT.	DESCRIPTION
1	1	VENTED ENCLOSURE, WATER PLUS CORP. MODEL #131632 COLOR PURPLE
2		AIR RELEASE VALVE 2" NPT (SEE BELOW) SEWER AIR RELEASE VALVES SHALL BE ARI MODEL D-025 P WATER AIR RELEASE VALVES SHALL BE VALMATIC OR EQUAL
3	1	1" CURB STOP, S.S.
4	1	2" x 4" NIPPLE, S.S.
5	1	2" BALL VALVE, S.S.
6	1	2" TEE, S.S.
7	1	2" X 1" REDUCER, S.S.
8	1	1" SHORT NIPPLE, S.S.
9	1	2" PIPE, S.S. LENGTH AS REQUIRED
10	1	2" DOUBLE STRAP TAPPING SADDLE, S.S.
11	1	4" & LARGER PIPE, D.I. OR PVC (SDR18)
12	2	2" CORPORATION BRASS
13	1	1-1/2" PIPE, PVC, LENGTH AS REQUIRED
14	1	1-1/2" x 90° ELBOW, PVC
15	1	CONCRETE SLAB AROUND ENCLOSURE
16		#57 WHITE ROCK

NOTES:

1. CITY OF PORT ORANGE SHALL HAVE THE OPTION OF REQUIRING THE AIR RELEASE VALVE ASSEMBLY WITH ODOR CONTROL SYSTEM TO BE INSTALLED WHERE ODOR MAY BE A CONCERN.



STANDARD CONSTRUCTION DETAIL
ABOVE GROUND SEWER AIR RELEASE
VALVE ASSEMBLY

REV. 12/18

FILE NAME:

S21.DWG

DETAIL REF:

S-21