



MATERIALS		
ITEM	QUANT.	DESCRIPTION
1	1	ENCLOSURE, WATER PLUS CORP. #131632, COLOR PURPLE
2	1	AIR RELEASE VALVE 2" NPT, ARI MODEL D-025P
3	1	1" CURB STOP, S.S.
4	1	2" x 4" NIPPLE, S.S.
5	1	2" BALL VALVE, S.S.
6	1	2" TEE, S.S.
7	1	2" X 1" REDUCER, S.S.
8	1	1" SHORT NIPPLE, S.S.
9	2	3" PIPE, PVC, LENGTH AS SHOWN, PERFORATED TOP HALF ONLY
10	2	3" CAP, PVC
11	1	2" PIPE, S.S. LENGTH AS REQUIRED
12	1	2" DOUBLE STRAP TAPPING SADDLE, D.I.
13	1	4" & LARGER PIPE, D.I. OR PVC (SDR18)
14	1	2" CORPORATION BRASS
15	2	1-1/2" PIPE, PVC, LENGTH AS REQUIRED
16	1	1-1/2" x 90° ELBOW, PVC
17	1	2" X 1-1/2" REDUCER, PVC
18	1	3" X 2" FLEX COUPLING
19	1	3" PIPE, PVC, LENGTH AS REQUIRED
20	1	3" x 90° ELBOW, PVC
21	1	3" PIPE, PVC, LENGTH AS SHOWN, PERFORATED TOP HALF ONLY
22	1	3" TEE, PVC
23	1	CONCRETE SLAB AROUND ENCLOSURE

NOTES:

- CITY OF PORT ORANGE SHALL HAVE THE OPTION OF REQUIRING THE AIR RELEASE VALVE ASSEMBLY WITH ODOR CONTROL SYSTEM (DETAIL S-32) TO BE INSTALLED WHERE ODOR MAY BE A CONCERN.



STANDARD CONSTRUCTION DETAIL
 ABOVE GROUND SEWER AIR RELEASE VALVE ASSEMBLY
 WITH ODOR CONTROL SYSTEM

REV. 12/18

FILE NAME:

S22.DWG

DETAIL REF:

S-22