



**NOTES:**

1. ON TRANSITIONS BETWEEN LARGER AND SMALLER DIAMETER SEWER COLLECTORS, THE TOP OF THE INSIDE OF THE TWO SEWER PIPES SHALL BE MATCHED.
2. NON-PENETRATING PICK-HOLES IN ALL CONCRETE SECTIONS.
3. USE FARBERTITE BITUMASTIC SEALER BETWEEN SECTIONS OF MANHOLES.
4. MAXIMUM DEPTH NOT TO EXCEED 15' MEASURED FROM MANHOLE TOP TO INSIDE BOTTOM.
5. 0.1' PIPE ELEVATION DROP ACROSS MANHOLE.



STANDARD CONSTRUCTION DETAIL  
SANITARY SEWER STANDARD MANHOLE

REV. 12/18

FILE NAME:	S6.DWG
DETAIL REF:	S-6