



CITY COUNCIL AGENDA ITEM

REQUESTED COUNCIL MEETING DATE 06/16/09

Subject: Emergency Repairs to Drainage Pipe on Wood Street.
Department: Public Works.

Recommended Motion:

Staff recommends approval to have Progressive Contractors Inc. make repairs to the drainage pipe and structure on Wood Street for a total cost not to exceed \$57,308.00.

Summary:

During the rainstorms last week, a storm water pipe on Wood Street separated from its concrete structure and began to buckle and lift out of the ground. This is a major drain from roadways to the retention pond on Wood Street. Staff has obtained a quote from Progressive Contractors Inc. to make the necessary emergency repairs. As shown on the estimate attached, Progressive will furnish and install 36" storm pipe, headwall and inlet for a cost of \$57,308.00. Funding source Account #10810005803414, Project ZEM109.

Attachments: Ordinance Resolution Budget Resolution

Other Support Documents/Contracts Available for Review in Manager's Office
Progressive Contractors Inc. Repair Estimate

Department Head *[Signature]* Submitted Date 5/29/09

Finance Department *[Signature]* Approved as to Budget Requirements Date 5/29/09

City Attorney Approved as to Form and Legality Date

City Manager *[Signature]* Approved Agenda Item For Date 6/16/09

COUNCIL ACTION: Approved as Recommended Disapproved

Tabled Indefinitely Continued to Date Certain Approved with Modification

MEMORANDUM

TO: Kenneth W. Parker
City Manager

DATE: May 29, 2009

FROM: Warren Pike *WP*
Public Works Director

SUBJECT: Agenda Item for June 16, 2009

Please place approval to have Progressive Contractors repair the pipe on Wood Street on the Council agenda for June 16th.

Commentary

During last week's rainstorms, a large drainage pipe on Wood Street separated from its concrete structure near the railroad tracks. This pipe allowed stormwater to drain from roadways to the retention pond on Wood Street.

Once separated from the structure, the pipe began buckle and lift out of the ground. Staff has obtained a quote from Progressive Contractors Inc. in the amount of \$57,308.00 to make the necessary emergency repairs. They will install 36" pipe, headwall and inlet and provide the de-watering and by-pass pumping.

Funding: Account 10810005803414, Project ZEM109.

Recommendation

Staff recommends approval to have Progressive Contractors Inc. make repairs to the drainage pipe on Wood Street for a cost not to exceed \$57,308.00.



Progressive Contractors, Inc.

3702 Olson Drive • Daytona Beach, Florida 32124

Sewer, Water, Storm Drainage

386 - 258-3807

Fax 386 - 258-3788

May 28, 2009

*Mr. Warren Pike
Public Works Director
City of Port Orange
407 Virginia Avenue
Port Orange, Fl 32127*

*Proposal – Woodstreet
36" Pipe Replacement*

We propose to furnish and install 36" RCP, headwall and inlet including de-watering and by-pass pumping for the:

Lump sum price of \$ 57,308.00.

If you have any questions, please contact me at (386) 258-3807.

Sincerely,

*Gerald Randall
President*